



## Cogswell District Energy Feasibility Study

---

HRM - Environment & Sustainability  
Standing Committee (ESSC)

October 6th, 2016



Delivering Quality & Value  
For Over 70 Years



# District Energy at Halifax Water

- 2010 investigation demonstrated feasibility in Bedford (Mill Cove WWTF) and downtown Halifax (Halifax WWTF)
- 2016 Feasibility study completed by DEC Engineering for Halifax Water shows a positive business case for a DES within the Cogswell redevelopment area
- Ambient Temperature DES shown to be the most promising, cost effective and efficient system for the Cogswell redevelopment area

# Benefits of District Energy

- Improved Energy Efficiency
- Improved Local Air Quality
- Reduced GHG Emissions
- Environmental Protection
- Energy Resilience & Access
- Ease of Operation & Maintenance
- Reliable, Proven Technology
- Comfort & Convenience
- Decreased Life-Cycle Costs
- Decreased Developer Costs
- Decreased Building Capital Costs
- Improved Architectural Design Flexibility
- Improved Marketability & Value of Real Estate

# High vs. Ambient Temperature?

- Refers to the temperature at which the heat transfer fluid is delivered to the customer.
  - High temperature ~ 70 to 90 °C
  - Ambient temperature ~ 10 to 25 °C
- Ambient Temperature DES Advantages:
  - **Lower capital cost** – no large energy center
  - **Modular build out** – delivers only energy that is needed
  - **Less DES piping losses** – better energy efficiency
  - **Individual back-up systems in each building** – better security of supply
  - **Opportunities for heat recovery and renewable supply**
    - Distributed Solar
    - Building Heat Sharing
    - Connected CHP

# District Energy Systems – Proven Technology

- Cheakamus Crossing ATDES, Whistler, BC (2010, WW Effluent)\*  
<https://www.whistler.ca/services/water-and-wastewater/district-energy-system>  
<http://www.cheakamuscrossing.ca/>
- Southeast False Creek DHS, Vancouver, BC (2010, Raw Sewage)\*  
<http://vancouver.ca/home-property-development/southeast-false-creek-neighbourhood-energy-utility.aspx>  
<http://vancouver.ca/docs/planning/renewable-energy-neighbourhood-utility-factsheet.pdf>
- Saanich ATDES, Victoria, BC (2011, WW Effluent)\*  
<https://www.crd.bc.ca/project/past-capital-projects-and-initiatives/saanich-peninsula-water-transmission-main-heat-recovery>  
<https://www.pembina.org/reports/ctax-casestudy-saanich.pdf>
- Markham District Energy, Markham, ON (2000 + 2012, NG CHP)\*  
<http://www.markhamdistrictenergy.com/>  
<https://www.markham.ca/>
- Alexandra DEU, Richmond, BC (2015, AT Geo-Exchange)\*  
<http://www.richmond.ca/sustainability/energysrvs/districtenergy/energyutility.htm>
- Ball State University, Muncie, IN (2013, Geo-Exchange)  
<http://cms.bsu.edu/about/geothermal>
- University of British Columbia, Kelowna, BC (2011, AT Geo-Exchange)  
<http://facilities.ok.ubc.ca/geoexchange/des-operation.html>
- Many other Canadian, US, European and Asian Applications

\* Examples of municipally mandated district energy systems

# Cogswell DES – Energy from Wastewater





Image Credit: Ekistics Planning & Design

# Halifax WWTF Effluent Heat Capacity



Effluent Temp	Heat Capacity @ Flow	
	2,000 m <sup>3</sup> /h	3,500 m <sup>3</sup> /h
14 °C	17 MW	31 MW
12 °C	13 MW	22 MW
10 °C	8 MW	14 MW
8 °C	3 MW	6 MW

# Halifax Heating Energy Source Comparison

	Electric Baseboard Heating	Air Source Heat Pump Heating + Cooling	Gas Hydronic Heating (BAU) <sup>(4)</sup>	Oil Hydronic Heating	ATDES Heating + Cooling
<b>Energy</b>	1 MWh				
<b>Fuel Source</b>	Electricity	Electricity	Natural Gas	Heating Oil	Electricity + DES
<b>Efficiency</b>	100%	240%	85%	80%	<b>420%</b>
<b>Fuel Use</b>	1.00 MWh Electricity	0.42 MWh Electricity	1.18 MWh Natural Gas	1.25 MWh Heating Oil	<b>0.24 MWh (Electricity) 0.76 MWh (DES)</b>
<b>Fuel Rate (\$/MWh)</b>	\$149.54 <sup>(1)</sup>	\$149.54 <sup>(1)</sup>	\$50.40 <sup>(2)</sup>	\$69.70 <sup>(3)</sup>	\$149.54 <sup>(1)</sup>
<b>Fuel Cost (\$/MWh Delivered Heat)</b>	\$149.54	\$62.81	\$59.47	\$87.13	<b>\$35.60</b>
<b>GHG Emissions (tCO<sub>2</sub>e/MWh Delivered Heat)</b>	0.652	0.274	0.212	0.313	<b>0.166 <sup>(5)</sup></b>

**Notes:**

- (1) Based on NSPI Rate Class 2 – Domestic, May 2016.
- (2) Based on Heritage Gas, Rate 1 – Residential, May 2016
- (3) Based on #2 Fuel Oil @ \$0.75/L
- (4) BAU = Business As Usual
- (5) Does not include GHG emissions from back-up heat source (NG)



# Preliminary Financial Analysis

	DES	BAU
Levelized Rate <sup>(1)</sup>	\$0.079/kWh	\$0.092/kWh
Capital Costs <sup>(2)</sup>	\$39,762	\$32,696
Present Value <sup>(3)</sup>	\$19.8M	\$23.2M
Net Present Value <sup>(3)</sup>	\$2.28M	
Internal Rate of Return <sup>(3)</sup>	5.7%	


**Notes:**

(1) Year 1 Levelized Rate – includes energy + capital + operating costs.

(2) Ref. DEC Report (June 2016) – Appendix D, Detailed Capital Cost Estimates.

(3) Ref. DEC Report (June 2016) – Section 7.1, Cost Comparison, for financial assumptions.

# Preliminary Financial Analysis



# Conclusions

1. Initial analysis shows a **positive business case** for the Cogswell DES.
2. The Cogswell DES project would demonstrate **environmental leadership** in the community.
3. Ambient Temperature DES from wastewater heat recovery is a **demonstrated and reliable** solution.
4. Halifax WWTF effluent has **sufficient thermal energy** to meet the heating and cooling requirements of the proposed DES loads and much more.
5. The DES can offer the customer thermal energy **more cost effectively** and with **more rate stability** compared to conventional natural gas, electricity, or heating oil systems.

# Conclusions

6. Halifax Water ownership advantages include:
  - Existing operating expertise;
  - Existing billing and customer service systems;
  - Lower cost of financing;
  - Secure public utility.
7. The proposed DES would likely be considered a “public utility” under the definition of the *Public Utilities Act* and interpretations provided by the Utilities and Review Board.
8. Cogswell DES Business Case depends on mandatory connection to the system within the Cogswell development area. Additional customer connections would improve the energy rate and the business case.

# Next Steps

1. With support from the ESSC, request HRM Council to **mandate connections** to the DES within the Cogswell re-development area, thus providing the exclusive right to provide thermal energy. Potential methods for mandatory connection include development agreements, restrictive covenants, or municipal by-laws.
2. Complete a **preliminary design** (including technology and regulatory review) and update the business case. If positive, seek formal approvals and initiate integration into the Cogswell project.
3. Continue to **share findings** with stakeholders (e.g. HRM, NSDOE, NSUARB, NRCan, QUEST, DND).
4. Investigate the potential for **connecting the DES to buildings outside of the Cogswell redevelopment area as a competitive energy source** in order to further improve the financial performance of the DES.

# Cogswell Ambient Temperature DES

*An **Ambient Temperature District Energy System (ATDES)** can deliver energy more efficiently and affordably than alternative systems while saving GHG emissions and reducing dependence on fossil fuels.*

*An ATDES can **provide value** to Halifax Water, HRM, developers, the customer, and the Cogswell development.*



**Thank you!**

**For Further Information Contact:**

Jeff Knapp, P.Eng., FEC, CEM  
Manager, Energy Efficiency  
Halifax Regional Water Commission  
(902) 471-2791  
[jeffreyk@halifaxwater.ca](mailto:jeffreyk@halifaxwater.ca)